



SGS Servizi Tecnici Industriali S.r.l.

Via G. Gozzi, 1/A
20129 Milano
Tel.: (02) 7393.1
Telex: 322202 SGSITA I
Fax: Div. INCO (02) 70125067

Milan, 22.02.99
DIN/AZ/GS
000.332.46

**Rapporto
Report**

No. 99.30.35.042

Attestation of conformity

Manufacturer: **Reichle & De-Massari AG**
Binzstrasse 31 – CH 8622 Wetzikon – Switzerland

Product(s) description: - **Unshielded Category 5e - 100Ω**
Outlet Connection Module 1x RJ45 - R925371

- **Shielded Category 5e - 100Ω**
Outlet Connection Module 1x RJ45 - R925370 –

- **Plugs R&M freenet Class E/F – Type 7454**

Samples of the products were tested and found in conformity with:

SP No. 4195-A : 1998 Proposed Addendum No. 5 to ANSI/TIA/EIA-568-A
“Additional Transmission Performance Specifications for 4-pairs 100 Ω Enhanced Category 5 Cabling”

Sub-clauses 10.4.4.1 “Attenuation” and 10.4.4.4 “DC Resistance” of
ANSI/TIA/EIA-568-A : 1995 “Commercial Building Telecommunications Cabling Standard”

The results of the tests performed are detailed in our test report No. 99.30.35.042, which is integrant part of this Attestation of Conformity.

Prepared
A. Zani

Verified
G. Sartori

Membri del Gruppo **SGS** (Société Générale de Surveillance)

Sede Legale Milano Via G. Gozzi, 1/A - Capitale int. versato Lire 2.000.000.000 - Tribunale di Milano N. 328942 - C.C.I.A.A. Milano N. 1403074 - Cod. Fisc./Partita IVA N. 10652000158